

Technical Opinion FC10138-01-C1 Issue 2

Technical Opinion Summary



This is to certify that the specimens described below have been examined by BRANZ on behalf of the sponsor.

Sponsor

Reynaers Aluminium N.V./S.A.
Oude Liersebaan 266
2570 Duffel
Belgium

Reference BRANZ Reports Technical Opinion FC10138-01-C1 Issue 2

Referenced Standard AS 1530.4:2014

Specimen Name: Reynaers CS 77-FP Glazed Screens and Doorsets

Specimen Description: Glazed screens constructed with the Reynaers CS 77-FP30 and CS 77-FP60 aluminium profiles, as described in test reports 2008-Efectis-RO0798 and 2008-Efectis-RO0171, together with Pilkington Pyrostop® or AGC Pyrobel® insulating glass of the maximum size as stated in Table 1 overleaf.

Glazed doorsets constructed with the Reynaers CS 77-FP30 and CS 77-FP60 aluminium profiles, as described in Efectis summary report 2008-Efectis-RO0934, subject to the conditions included in the report, together with Pilkington Pyrostop® or or AGC Pyrobel® insulating glass of the maximum size as stated in Table 2 overleaf.

Orientation: Exposure from either side.

The assessed results were as follows

See page 2 for the assessed performance for each glazed screen and doorset.

Issued by

A blue ink signature of M. E. Godkin.

M. E. Godkin
Senior Fire Testing Engineer

Reviewed by

A blue ink signature of E. Soja.

E. Soja
Senior Fire Safety Engineer

Regulatory authorities are advised to examine FC10138-01 Issue 2 before approving any product.

Issue Date
22 August 2022

Expiry Date
22 August 2027

This document is the property of ACM Fabricators Ltd and may not be reproduced, distributed, or disclosed without prior written consent

branz.nz | 1222 Moonshine Rd, RD1, Porirua 5381, Private Bag 50 908, Porirua 5240, New Zealand | Phone +64 4237 1170 | branz@branz.co.nz

Glazed screens and single and pair leaf doorsets with Pilkington Pyrostop® and AGC Pyrobel® glass

Product Code	Nominal thickness (mm)	FRL (minutes)	Max. Pane Dimension (mm)	Max. Pane Area (m²)
Pyrostop® 30-10	15	-/30/30	2,090	2.91
Pyrobel® 17N or 17N EG	17	-/30/30	2,860	3.15
Pyrostop®30-20	18	-/30/30	2,090	2.91
Pyrostop®60-101	23	-/60/60	2,090	2.92
Pyrobel® 25 or 25 DGU	25	-/60/60	2,700	3.84
Pyrostop®60-201	27	-/60/60	2,090	2.92

This document is the property of ACM Fabricators Ltd and may not be reproduced, distributed, or disclosed without prior written consent

branz.nz | 1222 Moonshine Rd, RD1, Porirua 5381, Private Bag 50 908, Porirua 5240, New Zealand | Phone +64 4237 1170 | branz@branz.co.nz